Swans Nest Metropolitan District

August 2026

Prepared by Gabby Begeman and Jared Herzing

Analytical Results:

1) Total Coliform test from 400 Revette came back absent.
2) Monthly operations report completed and sent to the state without violations.
3) Distribution Water Manganese (Treatment required if greater than 0.050 mg/l)
    a. Average from weekly samples = 0.004 mg/l
    b. Low: 0.000 mg/l
    c. High 0.007 mg/l
4) Entry Point Water Manganese
    a) Average from weekly samples = 0.007 mg/l
    b) Low 0.005 mg/l
    c) High 0.009 mg/l
5) Distribution Iron testing
    d) Average from weekly samples = 0.03 mg/l
    e) Low 0.00 mg/l
    f) High 0.05 mg/l

Other Items:

1. Conducted backflow protection and cross connection surveys, everything was in compliance.

Production Report

Year	Month	Well Production	Distribution Production	Metered Usage	Discrepancy Dist/Metered	Discrepancy Well/Metered
2026	Jan	323873	388144	315738	18.65%	2.51%
	Feb	321076	321320	295622	8.00%	7.93%
	Mar	341556	330784	325866	1.49%	4.59%
	Apr	281841	256528	236677	7.74%	16.02%
	May	552216	813408	585876	27.97%	-6.10%
	Jun	1794284	1633680	1758890	-7.66%	1.97%
	Jul	1634753	1647646	1767940	-7.30%	-8.15%
	Aug	1914603	1956884	1586352	18.93%	17.14%
	Sep					
	Oct					
	Nov					
	Dec					
AVERAGE		7164202	7348394	6872961	8.48%	4.49%