Swans Nest Metropolitan District

September 2026

Prepared by Gabby Begeman and Jared Herzing

Analytical Results:

1) Total Coliform test from hydrant 007 came back absent.
2) Monthly operations report completed and sent to the state without violations.
3) Distribution Water Manganese (Treatment required if greater than 0.050 mg/l)
    a. Average from weekly samples = 0.003 mg/l
    b. Low: 0.000 mg/l
    c. High 0.007 mg/l
4) Entry Point Water Manganese
    a) Average from weekly samples = 0.004 mg/l
    b) Low 0.000 mg/l
    c) High 0.013 mg/l
5) Distribution Iron testing
    d) Average from weekly samples = 0.04 mg/l
    e) Low 0.00 mg/l
    f) High 0.09 mg/l

Other Items:

1. Finished flushing and inspecting hydrants. Test reports have been uploaded and can be found here: https://orcwaterllc.sharepoint.com/:f:/s/ORCWater/IgBkCME0Z5xlTre-3FqFthMuASH2nS3ByuryGw6uaaVa4ZY?e=8hPXf9

Production Report

Year	Month	Well Production	Distribution Production	Metered Usage	Discrepancy Dist/Metered	Discrepancy Well/Metered
2026	Jan	323873	388144	315738	18.65%	2.51%
	Feb	321076	321320	295622	8.00%	7.93%
	Mar	341556	330784	325866	1.49%	4.59%
	Apr	281841	256528	236677	7.74%	16.02%
	May	552216	813408	585876	27.97%	-6.10%
	Jun	1794284	1633680	1758890	-7.66%	1.97%
	Jul	1634753	1647646	1767940	-7.30%	-8.15%
	Aug	1914603	1956884	1586352	18.93%	17.14%
	Sep	828200	817088	959167	-17.39%	-15.81%
	Oct					
	Nov					
	Dec					
AVERAGE		7992402	8165482	7832128	5.60%	2.24%